

PITTSBURGH TESTING LABORATORY

ESTABLISHED 1881

PITTSBURGH, PA.

AS A MUTUAL PROTECTION TO CLIENTS, THE PUBLIC AND OURSELVES, ALL REPORTS
ARE SUBMITTED AS THE CONFIDENTIAL PROPERTY OF CLIENTS, AND AUTHORIZATION
FOR PUBLICATION OF STATEMENTS, CONCLUSIONS OR EXTRACTS FROM OR REGARDING
OUR REPORTS IS RESERVED PENDING OUR WRITTEN APPROVAL.

Order No. NY-5840Date April 22, 1952Laboratory No. 429341

OFFICIAL CONFORMANCE TEST OF WINDOW

YEARLY RETEST
SPECIFICATIONS DH-A1

ALUMINUM WINDOW MANUFACTURERS ASSOCIATION

Manufacturer: General Bronze Corporation

Designation: DHA-C Window

Maximum Size: 3'10" x 5'5-1/2"

Reported to: Manufacturer and Aluminum Window Mfgs. Association

AIR INFILTRATION at 25 m.p.h. equivalent wind velocity was 0.27 c.f.m.
per foot of sash perimeter for a sash perimeter of 18.47 feet. Spec-
ification maximum permissible was 0.75 c.f.m. per foot.

MAXIMUM DEFLECTION of horizontal sash members under specified loads-InchesMAXIMUM PERMISSIBLE

	<u>Horizontal</u>	<u>Vertical</u>	<u>Horizontal</u>	<u>Vertical</u>
Upper Top Rail				
Upper Meeting Rail				
Lower Meeting Rail				
Lower Bottom Rail				

Upper Top Rail
Upper Meeting Rail
Lower Meeting Rail
Lower Bottom Rail

MAXIMUM DEFLECTION of any aluminum window member under uniform load of _____ pounds per square foot.DEFLECTION - INCHES

WINDOW MEMBER SHOWING
MAXIMUM DEFLECTION

	<u>Actual</u>	<u>Maximum Permissible</u>

MATERIALSCONSTRUCTION

COMMENTS: The window unit submitted satisfactorily met the requirements of the current Aluminum Window Mfgs. Ass'n Specification DH-A1 in regards to air infiltration as indicated by the test results reported above.

3-General Bronze Corporation

1-Manufacturer & Aluminum Window Mfgs. Ass.

TEST ENGINEER

Respectfully submitted,
PITTSBURGH TESTING LABORATORY

Lawrence K. Jones
Lawrence K. Jones,
Manager, Special Test Section

Joseph Jera Approved For Release 1999/08/27 : CIA-RDP78-04133A000100060001-4

fld